



LOS ANGELES COUNTY ♦ DEPARTMENT OF PUBLIC HEALTH
ENVIRONMENTAL HEALTH
Bureau of Environmental Protection
Drinking Water Program
5050 Commerce Drive, Baldwin Park, CA 91706
(626) 430-5420 Fax (626) 813-3016



NOTICE OF VIOLATION

ENFORCEMENT NUMBER	CC0000137	DATE	7/8/2016
SYSTEM NAME	NEW APOSTOLIC CHURCH	SYSTEM ID	1907036
SITE ADDRESS	28877 BOUQUET CANYON RD, SAUGUS CA 91350	CLASS	TNC
OWNER NAME	NEW APOSTOLIC CHURCH		
MAILING ADDRESS	21913 CENTURION WAY, SAUGUS CA 91350		

California Health and Safety Code, Sections: 100825, 116275, 116650, 116555
California Code of Regulation, Title 22, Sections: 64431, 64432, 64463.1, 64463.4, 64465, 64530, 64533, 64535.2

Public water systems must comply with the primary and secondary drinking water standards.

To determine compliance with the primary and secondary drinking water standards, a public water system shall collect routine water sample(s) from each active and stand-by well(s). The water sample(s) shall be analyzed by an approved laboratory.

Monthly water sample(s) shall be collected for each treatment plant utilized by water systems to comply with the primary and secondary drinking water standards.

A water system is in violation of the primary and secondary drinking water standards when the post treatment water sample(s) result exceeds the Maximum Contaminant Level (MCL).

Public water systems that violate the primary and secondary drinking water standards MCL shall issue a Tier 1 public notice. The Tier 1 public notice shall be delivered in a manner designed to reach persons served within the required time period by mail, direct delivery, and publication in a local newspaper or by posting in conspicuous public places served by the water system. Tier 1 public notice posted in a conspicuous public area shall remain in place for as long as the violation continues but in no case less than seven (7) days.



LOS ANGELES COUNTY ♦ DEPARTMENT OF PUBLIC HEALTH
ENVIRONMENTAL HEALTH
Bureau of Environmental Protection
Drinking Water Program
5050 Commerce Drive, Baldwin Park, CA 91706
(626) 430-5420 Fax (626) 813-3016



NOTICE OF VIOLATION

ENFORCEMENT NUMBER	CC0000137	DATE	7/8/2016
SYSTEM NAME	NEW APOSTOLIC CHURCH	SYSTEM ID	1907036
SITE ADDRESS	28877 BOUQUET CANYON RD, SAUGUS CA 91350	CLASS	TNC
OWNER NAME	NEW APOSTOLIC CHURCH		
MAILING ADDRESS	21913 CENTURION WAY, SAUGUS CA 91350		

VIOLATION DESCRIPTION:

The MCL for nitrate (as nitrogen) is 10 mg/L.

Laboratory analysis of the post treatment water sample collected on June 21, 2016 revealed the concentration level of nitrate (as nitrogen) at 34.2 mg/L.

CORRECTIVE ACTION:

You are hereby directed by this Department to cease violating the primary and secondary drinking water standards at once.

You are required to repair or replace the malfunctioning water treatment plant. Monthly water sample(s) post treatment shall be collected and submitted to the Department at swslab@ph.lacounty.gov.

The Tier 1 Public Notice shall be hand delivered to persons served by the water system and/or the notice shall be posted in conspicuous locations throughout the water system service area within 24 hours.

Certification of delivery and/or posting of the Tier public Notice must be completed and returned to EH at swslab@ph.lacounty.gov.

You may contact the Drinking Water Program at 626-430-5420 for any questions regarding this enforcement action.

Lusi Mkhitarian
Chief Environmental Health Specialist

Enclosure: Tier 1 Public Notice
Certification for Tier Public Notice